



PROJECT ASSURE DIAMOND VERIFICATION INSTRUMENT STANDARD TEST RESULTS

Assessment Report for: Smart Pro Instrument Co., Ltd. / AURA V2



Prepared For: Luc Auer

Natural Diamond Council Belgium VOF

Hoveniersstraat 22 2018 Antwerpen

Received Date: January 17th 2023

Assessment Dates: January 31 to February 17, 2023

Testing ID Number: 2023-01 Report Date: March 8, 2023

Approved by:

Quinten Van Avondt Lab Manager





SmartPro Instrument / Aura V2

Date: March 8th, 2023

Testing ID:

2023-01

DIAMOND VERIFICATION INSTRUMENT

Manufacturer's Name: SmartPro Instrument

Instrument Model: AURA V2
Serial Number: SPAU2-S02008

Software Version: 3.2

Lab Manager:Quinten Van AvondtTesting Manager:Cindy De Plukker

Manufacturer stated diamond verification instrument description and features:

- Manual stone feed
- Automated test results (synthetic diamond) / user interpretation (natural diamond or referral)
- Single stone and bulk testing (also in plastic bags)
- Results : synthetic , natural or referral

Manufacturer stated diamond verification instrument limitations:

- Loose stones
- Mounted jewelry
- Stone size: 0.8 mm and above (0.002ct and above)
- Stone color: colorless to near colorless (D-K)

INSTRUMENT PERFORMANCE ASSESSMENT

ASSESSMENT CRITERIA

The ASSURE testing methodology and performance metrics are dependent on the operational capabilities of the diamond verification instrument being tested. These are defined by the following three categories:

Category 1- Screen diamonds from synthetic diamonds. This category of device is intended for discrimination of diamonds from synthetic diamonds. It cannot distinguish diamonds from diamond simulants and therefore requires stones to be pre-screened to ensure no simulants are introduced into the device.

Category 2 – Screen diamonds from synthetic diamonds and diamond simulants. This category of device is intended for discrimination of diamonds from synthetic diamonds <u>and</u> diamond simulants. This device <u>cannot</u> distinguish synthetic diamonds from diamond simulants.

Category 3 – Screen diamond from synthetic diamonds from diamond simulants. This category of device is intended for discrimination of diamonds, synthetic diamonds and diamond simulants from each other. This device <u>can</u> distinguish synthetic diamonds from diamond simulants.



	SmartPro	Instrument <i>i</i>	/ Aura \	٧2
--	----------	---------------------	----------	----

Date: March 8th, 2023 Testing ID: 2023-01

Instrument performance for classifying the different kinds of stones was assessed against:

Diamond Verification Instrument Standard Part 1 – Diamond Verification Instrument for Screening Diamonds from Synthetic Diamonds (09 11 2021)

Diamond Verification Instrument Standard Part 2 – Diamond Verification Instrument for Screening Diamonds from Synthetic Diamonds and Diamond Simulants (09 11 2021)

Diamond Verification Instrument Standard Part 3 – Diamond Verification Instrument for Screening Diamonds, Synthetic Diamonds, and Diamond Simulants (09 11 2021)

as referenced in sections 7.3 and 7.4 of the Diamond Verification Instrument Standard – General Requirements for Evaluation Diamond Verification Instruments (09 11 2021). Any deviations from the Standard are noted below:

The Aura can screen Moissanite, however ASSURE Diamond Simulant testing was not done since the Aura can't screen cubic zirconium, synthetic sapphire and glass, which are part of the ASSURE Simulant test sample.

Bulk testing in plastic bags was not ASSURE tested.



SmartPro	Instrument /	/ Δura \	12
Jiliai ti TO	111361 011161167	Auia 1	, _

Date: Marc

March 8th, 2023

Testing ID:

2023-01

DEFINITIONS:

Diamond Accuracy	Diamond test stones correctly classified as Diamond.
Synthetic Diamond Accuracy	Synthetic Diamond test stones correctly classified as Synthetic diamond.
Diamond Referral Rate	Diamond test stones classified as Referral.
Synthetic Diamond Referral Rate	Synthetic diamond test stones classified as Referral
Diamond False Positive Rate	Synthetic diamond test stones incorrectly classified as Diamond
Synthetic Diamond False Positive Rate	Diamond test stones incorrectly classified as Synthetic Diamond
Diamond False Negative Rate	Diamond test stones incorrectly classified as Synthetic Diamond
Synthetic Diamond False Negative Rate	Synthetic Diamonds incorrectly classified as Diamond.
Testing Speed	The average speed at which the diamond verification instrument evaluates the stones in the PRIMARY loose sample set, including set-up time (if any).
Operating Speed	For auto-loading diamond verification instruments only, the average speed at which stones are evaluated once the instrument achieves a steady-state. Does not include set-up time.

TEST STONE SETS USED FOR EVALUATION

Loose, Polished Stone Test Sets	Diamond	Synthetic Diamond	Diamond Simulant
Primary Sample Set (>2.0 mm, D-J color)	\boxtimes	\boxtimes	
Supplementary Smalls Sample Set (1.0-2.0 mm, D-J color)	\boxtimes	\boxtimes	
Mounted, Polished Stone Test Sets	Diamond	Synthetic Diamond	Diamond Simulant
Primary Sample Set (>2.0 mm, D-J color)	\boxtimes	\boxtimes	
Supplementary Smalls Sample Set (1.0-2.0 mm, D-J color)	\boxtimes	\boxtimes	

Notes: none

CLEANING PROCEDURE OF STONES PRIOR TO TESTING

Test stones sets are cleaned in an ultrasonic bath of isopropanol for 2 minutes and dried prior to testing to reduce grease and electrostatic charge, as per Section 8 of ASSURE Standard.



SmartPro	Instrument /	/ Aura \	12
Jiliai ti TO	111361411161167	Auia 1	, _

Date: Mare

March 8th, 2023

Testing ID:

2023-01

LABORATORY CONDITIONS AT TIME OF ASSESSMENT

Condition	Requirement	Actual
Temperature (°C)	18 to 25°C	19 °C
Humidity (%)	50 to 65%	51 %

RESULTS OF INSTRUMENT PERFORMANCE ASSESSMENT – LOOSE STONES

Performance Metric	Primary	Uncertainty ^[1]	Smalls	Uncertainty ^[1]
Diamond accuracy (%)	97.1	2.0	97.1	2.0
Synthetic diamond accuracy (%)	89.3	3.7	90.0	0.0
Diamond referral rate (%)	2.5	1.9	2.1	1.2
Synthetic diamond referral rate (%)	8.3	2.3	9.0	0.0
Diamond false positive rate (%)	2.3	1.3	1.0	0.0
Synthetic diamond false positive rate (%)	0.4	0.1	0.8	0.8
Diamond false negative rate (%)	0.4	0.1	0.8	0.8
Synthetic diamond false negative rate (%)	2.3	1.3	1.0	0.0

Notes: [1] Uncertainty is expressed as absolute +/- range and reflects the consistency of the instrument's classification of stones for each of the three trials performed with the ASSURE sample.

RESULTS OF INSTRUMENT PERFORMANCE ASSESSMENT – MOUNTED STONES

Performance metric	Primary	Small
Diamond accuracy (%)	95.8	93.6
Synthetic diamond accuracy (%)	76.1	100.0
Diamond referral rate (%)	3.7	6.4
Synthetic diamond referral rate (%)	21.7	0.0
Diamond false positive rate (%)	2.2	0.0
Synthetic diamond false positive rate (%)	0.5	0.0
Diamond false negative rate (%)	0.5	0.0
Synthetic diamond false negative rate (%)	2.2	0.0



SmartPro	Instrument /	/ Aura \	12
Jiliai ti TO	1113ti allielit <i>1</i>	- Auia 1	_

Date: | March 8th, 2023

Testing ID:

2023-01

INSTRUMENT TESTING SPEED ASSESSMENT

Testing Speed approximates the usage turnaround time that could be expected by a novice user of the diamond verification instrument and is determined by the time required to evaluate the performance of the diamond verification instrument on the Primary Loose stone test set:

- Testing Speed accounts for the time directly associated with stone assessment including loading stones, programming
 any applicable instrument measurement parameters, analyzing the stones, and segregating the analyzed stones into
 respective instrument classified groups.
- Testing Speed does not include the time to initially warm-up the diamond verification instrument (if applicable) nor the time to separate diamonds from synthetic diamonds for each of the instrument classified groups of analyzed stones.
- Testing Speed does not include time associated with interruptions to the testing process.

Diamond verification instruments that continuously load and analyze stones (i.e., autoloading diamond verification instruments) shall also be assessed for a steady-state Instrument Operating Speed.

Testing speed, and instrument operating speed if applicable, are measured in triplicate. The mean value is reported in the Speed Test Results table below. The Uncertainty reflects the absolute +/- range of the results measured over the three trials.

SPEED TEST RESULTS (PRIMARY LOOSE SAMPLE)

Category	Stones per hour	Uncertainty
Testing Speed (all devices)	377	20
Operating Speed (auto-loading devices)	n/a ^[1]	n/a ^[1]

Notes: [1] not applicable for this device , the device has manual feed

ADDITIONAL FINDINGS

None

********* End of Report *****